



77
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 398

Dated: 07/05/2024

FIRE SAFETY CERTIFICATE

Certified that the M.B.D.A.V. Senior Secondary School, Yusuf Sarai, New Delhi-110016 (ID: 1925199), comprised of three independent blocks, one block of G+1 upper floor & two blocks each of G+2 upper floors, but the school running at ground & first floor only, have complied with the fire prevention and fire safety requirement in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officers concerned of this department on 22/04/2024 in the presence of Sh. R.S. Panwar (Sr. Teacher) & Sh. Neeraj Gulati (ASO) and that the school building/premises is fit for occupancy class "Educational" (Group 'B') with effect from 07/05/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/05/2024 at New Delhi by

(ATUL GARG
DIRECTOR
DELHI FIRE SERVICE)

Copy to: -

1. The Principal, M.B.D.A.V. Senior Secondary School, Yusuf Sarai, New Delhi-110016
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times as seen during inspection. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

8.10.13
16/24